



## UROX.S25091 Smoke-automatic Fire Detectors

[Page Bottom](#)

### Smoke-automatic Fire Detectors

[See General Information for Smoke-automatic Fire Detectors](#)**RAVEL ELECTRONICS PVT LTD**

S25091

150 - A  
ELECTRONICS INDL ESTATE  
PERUNGUDI  
CHENNAI, TN 600096 INDIA

Detector			Compatibility	Velocity Range (fpm)	
Model	Application	Type	Restrictions	Min	Max
<b>RE316S-2(+), RE316S-2M(+), RE316SH-2(+), RE316SH-2M(+), RE316S-2L(+), RE316S-2LM(+), RE316SH-2L(+), RE316SH-2LM(+)</b>					
	OAP	P	D1	0	4000
<b>RE316S-4(+), RE316S-4M(+), RE316SH-4(+), RE316SH-4M(+)</b>					
	OAP	P	None	0	4000
<b>RE317A-S(+), RE317A-SH(+), RE317A-SL(+), RE317A-SHL(+)</b>					
	OAP	P	D1	0	4000
<b>RE317D-S(+), RE317D-SH(+), RE317D-SL(+), RE317D-SHL(+)</b>					
	OAP	P	D1	0	4000

Base Model	Related Detector	Control Unit Compatibility Restrictions
<b>772914(+), 782914(+)</b>	RE316S-2, RE316S-2M, RE316SH-2, RE316SH-2M, RE316H-2, RE316H-2M, RE317A-S, RE317A-H, RE317A-SH, RE317D-S, RE317D-H, RE317D-SH	None
<b>774914(+), 784914(+)</b>	RE316S-2L, RE316S-2LM, RE316S-4, RE316S-4M, RE316SH-2L, RE316SH-2LM, RE316SH-4, RE316SH-4M, RE316H-2L, RE316H-2LM, RE316H-4, RE316H-4M, RE317A-SL, RE317A-HL, RE317A-SHL, RE317D-SL, RE317D-HL, RE317D-SHL	None

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

OAP - Open Area Protection

P - Photoelectric

(+) - Suitable for use in ambient temperatures of minus 10 - 37.8C (14 - 100F).



Trademark and/or Tradename:

[Last Updated](#) on 2011-07-12

[Questions?](#)[Print this page](#)[Notice of Disclaimer](#)[Page Top](#)

Copyright © 2011 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and

covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

